

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. 476

Dated: 20.4.26

It is certified that an inspection team headed by Dr R. B. Yadav from CHC Cholapur inspected the ASHA PUBLIC SCHOOL Latauni Varanasi on 20/04/2026 and on the basis of Water Test Report (attached) bearing no. 1486 dated 06/03/2026 of Executive Engineer Jal Kal Vibhag Nagar Nigam , Varanasi certified that the ASHA PUBLIC SCHOOL LATAUNI has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State Govt.

This certificate is valid till 31/03/2027.

To
The Principal
ASHA PUBLIC SCHOOL
Latauni, Varanasi


अधीक्षक
सामुदायिक स्वा० केन्द्र
चौलापुर-वाराणसी
Signature With Seal
Name: Dr R. B. Yadav
Designation M.P.S.
Name & Address of the office
CHC Cholapur & Varanasi



APPENDIX-VIII

PROFARMA REGARDING SAFE DRINKING WATER

CERTIFICATE

NO 1486

Date: 06-03-2026

It is certified that an inspection team headed by Shambhu Nath

Chemist Incharge from Jalkal Vibhag Nagar Nigam

Bhelupur Varanasi inspected the आशा पब्लिक स्कूल, वाराणसी

on 28/02/26 and found that the Chemical and Bacteriological test of

water sample is satisfactory and potable.

The above valid for a period of 06 months.

Signature: [Signature]

Name: अधिकासी अधियन्ता (मु०,
जल कल विभाग
नगर निगम, वाराणसी

Designation: _____

To
आशा पब्लिक स्कूल
ललीही - वाराणसी

(Name & Address of the Institution)



जलकल विभाग नगर निगम, वाराणसी

TEST REPORT (As per IS 10500:2012)

Sr. No. 268

सं. 1486

रिपोर्ट - 06-03-2026

Details of Samples: Testing of water sample for drinking purpose and test required (As per IS 10500:2012)
Sample collected by :

Location : आशा प्राथमिक स्कूल - लतीली, वाराणसी - 221104

Test Date : 28/02/26 से 02/03/26

Witness of person : आशा प्राथमिक स्कूल - लतीली, वाराणसी (प्रबंधक)

Sl.No.	Parameter	Parameter Acceptable-Permissible	Observed Values	Remarks
1	pH Value	6.5-8.5	6.9	
2	Turbidity (NTU)	1-5 (NTU)	0.9	
3	Iron (Total Iron as Fe) mg/l)	0.3-1.0	0.5	
4	Sulphate (as So4) (mg/l)	200-400	288	
5	Chloride (as CL) (mg/l)	250-1000	341	
6	Residual Free Chlorine (Mg/l)	0.2-1.0	0.4	
7	Alkanity (mg/1 as CaCo3)	200-600	266	
8	Arsenic (as AS) (mg/l)	0.01-0.01	0.0	
9	MPN/100ml	0.0-0.0	0.0	
10	TDS (mg/l)	500-2000	362	
11	Colour (Hazen Units)	5-15	8	
12	Hardness (mg/l) as Caco3	200-600	315	
13	Fluoride (mg/l) as F	1.0-1.5	0.1	
14	Magnesium (PPM)	30-100	62	
15	Nitrate as No3	0.1-0.1	0.0	
16	Dissolved Oxygen (PPM)	0-20	9	
17	Taste & Odour	Unobjectionable	Unobjectionable	
18	Calcium (mg/l)	75-200	79	
19	Conductivity	200-800 /cm	318	

b. Report of suitability of water for drinking purpose

6/3/26
केमिस्ट
जलकल विभाग नगर निगम
वाराणसी
Signature Chemist